

Fig. 1





Fig. 2



Lighting Activity Report
Sorted by Group

Code Number	Date (MM/DD/YYYY)	Floor Number	Group Number	Number of Lamps	Number of Ballasts	Work Order Number	LAMP Group Percent Annual Failure Rate
abc1234567898	02/08/00	68	1	2		4421	
abc1234567899	03/08/00	68	1		1	3321	
abc1234567916	03/08/00	66	1	2		3321	
abc1234567917	04/08/00	66	1	2		7765	
abc1234567934	08/08/00	65	1	2		6654	
abc1234567935	26/07/00	63	1	2		6648	
abc1234567952	07/07/00	63	1	2		8843	
abc1234567953	07/08/00	63	1			2289	40.00%
abc1234567897	12/07/00	47	2	2		2314	
abc1234567900	03/08/00	47	2	2		4421	
abc1234567915	03/07/00	46	2		1	4432	
abc1234567918	30/08/00	45	2	2		7789	
abc1234567933	03/07/00	44	2	2		7754	
abc1234567936	21/07/00	43	2	2		8808	
abc1234567937	04/08/00	60		2		6633	
abc1234567942	26/08/00	59	8	2		9123	
abc1234567945	08/07/00	58				8878	40.00%
abc1234567890	23/08/00	54	9	2		1122	
abc1234567907	01/08/00	54	9	2		6666	
abc1234567908	30/09/00	53	9	2		5543	
abc1234567925	21/07/00	53	9	2		8855	
abc1234567926	05/08/00	7	9	2		8844	
abc1234567943	22/08/00	6	9	2		9988	
abc1234567944	21/08/00	6				7769	1200%
TOTAL				104	13		

TOTAL ANNUAL FAILURE RATE: LAMPS 3.47%
Total System: 3,000
BALLASTS 0.87%
Total System: 1,500

Fig. 3